



GENERAL NOTES:

1. Maximum barrel extensions are 18 in. and shall be Waterous extension for Waterous hydrants.
2. All hydrants shall be furnished with a 6" flanged x mechanical joint auxiliary valve that conforms to AWWA 500-80. All trim bolts shall be stainless steel.
3. ALL BELOW GRADE FASTENERS TO BE STAINLESS STEEL:
  - A. BOLTS AND THREADED RODS - GRADE #304
  - B. NUTS AND WASHERS - GRADE #300
4. MEGALUG Mechanical Joint Restraints shall be installed on all mechanical fittings.

NOT TO SCALE

REV:	KLM	DATE:
REV:	RMS	DATE: JUL 2004
DRAWN BY:	VV	DATE: JAN 2003

FIRE HYDRANT

VILLAGE OF VILLA PARK  
WATER