



GENERAL NOTES:

1. ALL BELOW GRADE FASTENERS TO BE STAINLESS STEEL:
 - A. BOLTS AND THREADED RODS - GRADE #304
 - B. NUTS AND WASHERS - GRADE #300
2. FRAME AND LID:
 - NEENAH R-1015-2000 FRAME
 - NEENAH R-1015-2001 SELF SEALING LID
 - "WATER" TO BE CAST INTO COVER

NOT TO SCALE

REV:	DATE:
REV: RMS	DATE: JUL 2004
DRAWN BY: VV	DATE: JAN 2003

WATER VALVE IN VAULT

VILLAGE OF VILLA PARK
WATER - 14